



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No. F6/DFS/MS/School/2023/NDZ/ 528

Dated: 03/08/2023

FIRE SAFETY CERTIFICATE

Certified that the Elite International School running at ground and first floor only of building comprised of ground plus two upper floors located at 2nd Pusta, Sonia Vihar, Delhi-110094, owned/occupied by Elite International School has already been issued FSC vide letter no. F6/DFS/MS/School/2019/NDZ/288 dated 05/02/2019. The premises was re-inspected by the officer concerned of fire service on 30/06/2023 in the presence of Mr. Naveen Kumar, Manager of the school and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 03/08/23... for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on03/08/2023.... at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

To,

The Manager
Elite International School, 2nd Pusta located at Sonia Vihar, Delhi-110094

Copy:-

The Dy. Director of Education,
B- Block, Yamuna Vihar, Delhi-110092

Conditions for the validity of Fire Safety Certificate:-

1. **Fire Safety Certificate is valid for ground and first floor only. Applicant has submitted an undertaking dated 07/06/2023 that he will not use second floor for school purpose failing which, FSC should be treated null & void.**
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

ELITE INTERNATIONAL SCHOOL


MANAGER