



C19
100

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001


No. F6/DFS/MS/School/2026/NDZ/ 67

Dated: 05/06/2026

FIRE SAFETY CERTIFICATE

Certified that the **Elite International School** located at **2nd Pusta, Sonia Vihar, Delhi- 110094**, comprised of Ground plus three upper floors, owned/occupied Elite International School was issued FSC vide letter No. F6/DFS/MS/School/2023/NDZ/528 dated 03/08/2023 (G+1). The premises was re-inspected by the officer concerned of this department on 22/05/2026 in the presence Sh. Naveen Kumar (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Educational" (Group-B) for G+3 with effect from 05/06/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 & also conditions printed below.

Issued on.....05/06/2026.....at New Delhi by.


5/6/26

(Dr. S. K. TOMAR)

CHIEF FIRE OFFICER

DELHI FIRE OFFICER

To,

1. The Manage, Elite International School at 2nd Pusta, Sonia Vihar, Delhi-110094
2. The Dy. Director of Education, B- Block, Yamuna Vihar, Delhi-110092

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

